



OFFICE OF THE MISSION DIRECTOR  
NATIONAL HEALTH MISSION, ASSAM  
SAIKIA COMMERCIAL COMPLEX, CHRISTAN BASTI, G.S ROAD, GUWAHATI-781005  
PH.NO : 0361-2363062 ; TELE FAX : 0361-2363058

Website: [www.nrhmassam.in](http://www.nrhmassam.in)

e-mail: [misnrhm.assam@gmail.com](mailto:misnrhm.assam@gmail.com)

**Tender No: NHM/PROC/ Online UPS & Voltage Stabilizer/2018-19/6181      Date:07/04/2017**

**CORRIGENDUM No. 1**  
**e-TENDER FOR RATE CONTRACT OF ONLINE UPS & VOLTAGE STABILIZER**

This has reference to the e-tender No: NHM/PROC/ Online UPS & Voltage Stabilizer/2018-19/6181      Date: 07/04/2017 for entering into rate contract for "Supply of Online UPS & Voltage Stabilizer" to health institutions in different districts of Assam. The following amendment may be taken note of prior to submission of Bids.

**1. ANNEXURE 1 - Item serial no 4. 5 KVA UPS (technical specifications) is amended to read as follows:**

Point no 3.1 , Input voltage should be 220/230/240 V

Point no 4.1, minimum back-up minimum VAH should be 12,480

Point no 3.1, Output power should be 5 KVA/4.5 KW.

**2. ANNEXURE 1 - Item serial no 5.6.7 & 8 Servo controlled voltage stabilizer (technical specifications) is amended to read as follows:**

Point no 3.1, Voltage range : 160-240 volts per phase

**3. ANNEXURE 1 - Item serial no 1.2.3 & 4 Online UPS (technical specifications) is amended to read as follows:**

Point no 3.1, Input parameters should have in-built Isolation transformer (1:1), can be in the input or output side

**Additional Points:**

1. The UPS can be configured in any of the configuration at site as per requirement of 1/1 phase, 3/1 phase, 3/3 phase and 1/3 phase.
2. The UPS must have IGBT based rectifier inverter.
3. Should have 3% Input THDI at full load
4. Dual input provision. Output efficiency of 96%.
5. Redundant communication port. Automatic by-pass and mutual maintenance by-pass.
6. Local service network with available spare parts for immediate rectification if any.

Sd/-  
Mission Director, NHM, Assam