



OFFICE OF THE MISSION DIRECTOR
NATIONAL HEALTH MISSION, ASSAM
SAIKIA COMMERCIAL COMPLEX, CHRISTAN BASTI, G.S ROAD, GUWAHATI-781005
PH.NO : 0361-2363062 ; TELE FAX : 0361-2363058

Website: <http://nhm.assam.gov.in>

e-mail: misnrhm.assam@gmail.com

Tender No: NHM/PROC/ Online UPS & Voltage Stabilizer/2018-19/6181

Date: 23/07/2018

CORRIGENDUM No. 2
e-TENDER FOR RATE CONTRACT OF ONLINE UPS & VOLTAGE STABILIZER

Corrigendum-1, point no 3 - Item serial no 1.2.3 & 4 Online UPS (technical specifications) is amended to read as follows:

Point no 3.1, Isolation transformer (1:1) will not be built –in and should be in the input side only.

Corrigendum-1, Additional Points is amended to read as follows:

1. The UPS can be configured in any of the configuration at site as per requirement of 1/1 phase, 3/1 phase, 3/3 phase and 1/3 phase. – not required as per our site requirement and hence stands cancelled.
3. Should have 3% Input THDI at full load – amended to THDI \leq 5%
4. Output efficiency of 96%.- amended to Output efficiency \leq 94%

Point no 2, 5 & 6 of **Corrigendum-1**, Additional Points will remain unchanged.

Additional Points

1. AVR to be available at input side.
2. 3 nos of chemical earthing required during installation.
3. In-built surge protection device
4. Auto – start up facility in the UPS.

All other terms and conditions of the tender referred to above shall remain unchanged. The end date of bid submission is extended to **03/08/2018 up to 2:00 PM** respectively.

Sd/-
Mission Director
NHM Assam